

Certificate of Product Ratings

AHRI Certified Reference Number : 214771569 Date : 08-26-2026 Model Status : Production Stopped

Brand Name : TUTTOKOOL

Model Number : TK1503

AHRI Type : SPY-A

Refrigerant Type : R-410A

Hertz : 60

Sold In? : USA

Rated as follows in accordance with the following test procedures and subject to verification of rating accuracy by AHRI-sponsored, independent, third-party testing:

-AHRI Standard 340/360-2022, Performance Rating of Commercial and Industrial Unitary Air-Conditioning and Heat Pump Equipment

-AHRI Standard 365-2009, Commercial and Industrial Unitary Air-Conditioning Condensing Units

Cooling Capacity 95F/Cooling Capacity 95F at 230v : 140000/140000

EER 95F/EER 95F at 230v : 11.00/11.00

IEER/IEER at 230v : 14.2/14.2

The following data is for reference only and is not certified by AHRI

Full Load Indoor Coil Air Quantity (scfm) : 4600

AHRI CERTIFIED®
www.ahridirectory.org

†“Active” Model Status are those that an AHRI Certification Program Participant is currently producing AND selling or offering for sale; OR new models that are being marketed but are not yet being produced. “Production Stopped” Model Status are those that an AHRI Certification Program Participant is no longer producing BUT is still selling or offering for sale.

Ratings that are accompanied by WAS indicate an involuntary re-rate. The new published rating is shown along with the previous (i.e. WAS) rating.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on “Verify Certificate” link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2026 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

CERTIFICATE NO.:

134322460527021738